



C.NO/63/FSCR/DFO/BELAGAVI/2024

Date : 03-09-2024

To,
The Principal,
The Army Primary School,
The Maratha LIRC,
Camp, Belagavi, Belagavi Taluk & District.

Sir,

Sub: Issue of "**Fire Safety Compliance Report**" to The Army Primary School, The Maratha LIRC, Camp, Belagavi, Belagavi Taluk & District.
Ref: 1) C.NO/63/ADV/DFO/BELAGAVI/2024 Date: 28-02-2024.
2) CNo:01/FSO/BELAGAVI/2024 Dated: 30-08-2024
*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of **The Army Primary School, The Maratha LIRC**. building consisting with Ground and 2 Upper floor situated at **Camp, Belagavi, Belagavi Taluk & District**. was inspected by Fire Station Officer, Belagavi on 30-08-2024 with respect to fire Prevention, Fire fighting and Evacuation measures complied in the above premises for issuing of **FSCR** & the details as under

ANNEXURE-1

(Up to 14.99 mtrs. In height)

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Principal, The Army Primary school, The Maratha LIRC, Camp, Belagavi, Belagavi Taluk & District.	
02	Name and Address of the Premises	The Army Primary school, The Maratha LIRC, Camp, Belagavi, Belagavi Taluk & District	
03.	Name and Address of the Building Owner	Central Government, The Army Primary school, The Maratha LIRC, Camp, Belagavi, Belagavi Taluk & District	
04.	Number of Building	04 Blocks	
05.	Number of Floors	1 st Block- Ground & 2 Upper Floors 2 nd Block-Ground Floor 3 rd Block-Ground Floor 4 th Block-Ground Floor	
06.	Floor-wise details of Occupancy:-		
	1 st Block	Ground Floor	The Army Primary school Class Room-05
		1 st Floor	The Army Primary school Class Room-05,
		2 nd Floor	The Army Primary school Class Room-05,

(Handwritten signature and date)
03/09/24

	2 nd Block	Ground Floor	PE Room-01, Class Room-05, Store Room-01				
	3 rd Block	Ground Floor	Principal Room-01, Exam department Room-01, Office Room-01, Staff Room-01, Sports Room-01, Computer Lab-01, First Aid Room-01,				
	4 th Block	Ground Floor	Class Room-08				
07.	Height of the building		1 st Block 10.35 mtr	2 nd Block 03.75 mtr	3 rd Block 06.50 mtr	4 th Block 04.36 mtr	
08.	Site area		6.225 acres				
09.	Built-up area of each floor:-	1 st Block	2 nd Block	3 rd Block	4 th Block		
		Ground Floor	316.79 Sq Mtr.	156.07 Sq Mtr	156.07 Sq Mtr	178.37 Sq Mtr	
		1 st floor	316.79 Sq Mtr.	-	-	-	
		2 nd Floor	316.79 Sq Mtr.	-	-	-	
10.	Total Built-up area		950.37 Sq Mtr.	156.07 Sq Mtr	156.07 Sq Mtr	178.37 Sq Mtr	
11.	Surrounding properties:-	East	Army Quarters				
		West	06.00 Mtr wide road				
		North	06.30 Mtr wide road				
		South	Jail Wing Battalion				
12.	Open Space all around the building	1 st Block	2 nd Block	3 rd Block	4 th Block		
		East	05.80 Mtr	13.24 Mtr	10.70 Mtr	03.30 Mtr.	
		West	14.45 Mtr	05.00 Mtr	13.25 Mtr	10.70 Mtr.	
		North	02.60 Mtr	02.75 Mtr	05.46 Mtr	09.90 Mtr.	
		South	02.75 Mtr	34.75 Mtr	07.30 Mtr	04.56 Mtr.	
Allowed Setbacks (open space) should be maintained free from further obstruction/construction.							

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No (01)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 06.30 Mtr wide road on the Northern Side		Adequate
02.	Number of Entrances	02 Nos. each of 5.40 Mtr wide gate		Adequate
03.	Number of Staircase	No of staircase	01	Complied
		Width of the staircase	1.15 Mtr	
		Width of threads	0.29 Mtr	
		Height of risers	0.15 Mtr	
		No of risers per flight	15	
		Height of the hand drill.	0.76 Mtr	

(Signature)
03/09/24

04.	Portable Extinguishers	<p>1st Block-04 Nos. 6 Kg ABC, 01 No. of 4.5 Kg CO2, 01 No of 9 Ltrs Foam type & 01 No. of 9 Ltrs capacity Water Mist type.</p> <p>2nd Block-02 Nos. 4 Kg & 2 nos. of 2 Kg capacity ABC type</p> <p>3rd Block- 02 Nos. 4 Kg & 2 nos. of 2 Kg capacity ABC type</p> <p>4th Block- 01 Nos. 4 Kg & 3 nos. of 2 Kg capacity ABC type extinguishers has been provided.</p> <p>All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.</p>	Complied
05.	Hose reel hose system	03 nos. of hose reel hose has been provided. The hose reel hose of min 19 mm size and of 30 mtrs length has been provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size. The hose reel hose is connected at staircase landing of the building.	Complied
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	The system has been connected to booster pump of 450 LPM capacity has been provided to the Block 01. Further the system also has been connected to alternative source of power supply.	Complied
07.	Diesel Generator	01 no. of 30 KVA capacity generator has been provided.	Complied
08.	Terrace Tank	01 No. of 5,000 ltr capacity overhead tank has been Provided.	Adequate
09.	Escape routes	Direction in which the students/teachers have to move in the event of emergency have been indicated in the corridor/passage as a guide during evacuation in each blocks.	Complied.
10.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency have been displayed in each block along with the telephone numbers of Belagavi Fire station i.e 0831-2429441, 101 & the telephone nos nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit of the each floor each block.	Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied

B. B. B.
03/09/24

13.	Nominate One Fire Nodal Officer	1) S.K. Haldar 2) Suraj ARP has been nominated as fire nodal officers	A Fire Nodal Officer shall be nominated either from teaching or non teaching staff.
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.
15.	<p><u>Fire Precautionary Measures</u></p> <p>A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</p> <p>B:-Accumulation of combustible waste in and around the premises should be avoided.</p> <p>C:- The Exit ways shall be always kept clear without any obstruction.</p> <p>D:-Liquefied petroleum gas should not be stored in the building.</p> <p>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</p> <p>F:- During the class hours the class room door shall not be locked from inside to out side.</p> <p>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</p>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing **"Fire Safety Compliance Report" to The Army Primary School, The Maratha LIRC, Camp, Belagavi, Belagavi Taluk & District.** As they have complied all the recommendations as per reference 1. With the condition that the staff should get trained in the basic fire fighting at Training Centre R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "FSCR" is valid for only one year from the date of issue and is renewable.



Yours Faithfully

(Signature)
03/09/24
District Fire Officer
Karnataka State Fire And Emergency Services
Belagavi-01.

Copy to,
Fire Station Officer, Belagavi.